

Tim Murphy - Club Secretary
Midland Gliding Club
Longmynd
Church Stretton
SY6 6TA

Shropshire Council
The Guildhall
Frankwell Quay
Shrewsbury
Shropshire
SY3 8HQ

Date: 23 April 2026
My Ref: 47980/334494
Your Ref

Dear Sir

**Private Water Supplies Regulations 2016 (Amended)
Re PWS Midland Gliding Club Spring, Midland Gliding Club, The Port Way,
Asterton, Church Stretton, SY6 6TA**

Please find enclosed certificate of analysis of the sample taken from at PWS Midland Gliding Club Spring, Midland Gliding Club, The Port Way, Asterton, Church Stretton, SY6 6TA on 15 April 2026.

The results of the analysis show that the supply does not satisfy the requirements of the Private Water Supplies Regulations 2016 (Amended) for the following parameters:

- Total Coliforms = 1 cfu/100ml

Total Coliforms should be showing at 0cfu/100ml. These are bacteria sometimes found in untreated water supplies, they can flourish in contaminated taps and in systems whose integrity can be compromised by the ingress of foreign matter/material.

A failing of Total Coliforms parameter can be indicative of the natural processes involved in the breakdown of organic material (vegetation) which has leached into the water system or from the faucet from which water was drawn for the sample analysed. Dependent on the distribution system there is the potential for more harmful pathogen to enter the supply.

Total coliforms give an indication of generalised contamination, such as decaying vegetation but are generally not considered harmful to health.

In view of this result, it is recommended that you check the system for any points where any contamination may be able to enter the distribution, e.g. any lids are whole and form a good waterproof, vermin proof seal & any storage tanks/reservoirs are of sound construction with vermin traps over any overflow.

Also, any treatment system fitted is serviced within the manufacturers' guidelines.




Based on the current classification of the supply, your next statutory sample will be due April 2027.

Thank you for your cooperation in this matter. You will either have already received an invoice for the cost of sampling, sample analysis and administration, or this will follow shortly.

Please contact me if you have any further queries in the meantime.

Yours sincerely

A handwritten signature in dark ink, appearing to read 'K Brummer', on a light-colored rectangular background.

Karl Brummer
Public Protection Officer
Environmental Resources & Public Health
Communities & Customer
karl.brummer@shropshire.gov.uk